



PSB Singapore

# CERTIFICATE OF CONFORMITY

No. CLS1B 17 06 97595 002

**Certificate Holder:** Gorter Group BV  
Harmenkaag 1  
1741 La Schagen  
THE NETHERLANDS

**Certification Mark:**



TÜV SÜD PSB

**Product:** Fire Rated Hatches

**Brand Name:** Gorter

**Model(s):** WAEI

**Product Details:** Integrity: 120 mins  
A steel floor hatch

**Standard(s):** BS 476-22:1987

**Country of Origin:** The Netherlands

**Test Report(s):** See CoC Appendix (1pg)

**Issued on:** 2017-06-08

**Valid until:** 2020-04-30

Products listed under Class 1B must have TÜV SÜD PSB PLS mark as shown above affixed/printed on them. Failure to comply with this requirement may result in revocation of this certificate.

Page 1 of 2

This Certificate is part of a full report and should be read in conjunction with it. This Certificate remains the property of TÜV SÜD PSB Pte Ltd and shall be returned upon request. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking TÜV SÜD PSB's website at [www.tuv-sud-psb.sg](http://www.tuv-sud-psb.sg)

Vice-President (Certification Department)  
TÜV SÜD PSB



Cert No: PD-2002-01

TUV®