

Numerical analysis of the thermal behaviour of Gorter RHT-0700-0900 roof hatch

Using EN ISO 10077: Thermal performance of windows, doors and shutters -
Calculation of thermal transmittance

- Part 1 (ISO 10077-1:2006/Cor.1:2009): General
- Part 2 (ISO 10077-2:2012): Numerical method for frames

SUMMARY

Prepared for the assignor: Gorter Group BV
Hermankaag 1
NL-1741 LS Schagen

Prepared by: Eurosolid Kft.
address: H-2040 Budaörs, Szép u. 26., Hungary
office: H-1117 Budapest, Szerémi út 7/B,
Hungary
tel.: +36 1 216 8661
e-mail: info@eurosolid.hu
web. www.eurosolid.hu

Csaba ZOMBOR
managing director, supervisor

Tamás SZATMÁRI
application engineer

Date of Submission: 19th of January, 2018





3.2. Results of the analysis

Thermal transmittance of the hatch: $U_w = 0,319 \text{ W/m}^2\text{K}$

Thermal resistance of the window: $R_w = 3,130 \text{ m}^2\text{K/W}$

Budapest, 19th of January, 2018

.....
Csaba ZOMBOR
managing director, supervisor

.....
Tamás SZATMÁRI
application engineer